



A-MARK

Product Certification Mark

PRODUCT CERTIFICATE OF CONFORMITY

Certification Scheme Type 5

This is to certify that the product and certificate holder detailed here-on complied to the Certification Requirements of ANQAS Certification Sdn. Bhd.

TRAPPED FLOOR GULLIES FOR BUILDING

is found to comply with

BS EN 1253-1: 2015

Certificate Holder : CHEZY INDUSTRIES SDN. BHD.
NO. 22, JALAN URANUS AK U5/AK,
TAMAN SUBANG IMPIAN,
40150 SHAH ALAM,
SELANGOR DARUL EHSAN, MALAYSIA.

Product Description : *Product Description shall refer to Appendix A*

Manufacturer : CHEZY INDUSTRIES SDN. BHD.
NO. 22, JALAN URANUS AK U5/AK,
TAMAN SUBANG IMPIAN,
40150 SHAH ALAM,
SELANGOR DARUL EHSAN, MALAYSIA.

Certificate No.:
L01621

Date of Initial
Certification:
16.03.2021

Date of Issue:
04.03.2022

Date of Expiry:
31.03.2023

Brand

Chezy

Certificate issued by:
ANQAS CERTIFICATION SDN. BHD.
(1290274-U)
D-02-16, Tingkat 1, Jalan Sri Kenari 14,
Taman Sri Kenari Fasa 2, 43000 Kajang,
Selangor Darul Ehsan, MALAYSIA.

Website: www.anqascertification.com
Tel : +603-3310 0031
: +603-8740 5737/9447
Fax : +603-8740 2287


AZMAN BIN IDRIS
Managing Director
ANQAS CERTIFICATION SDN. BHD.



PRODUCT CERTIFICATE OF CONFORMITY

Certificate Holder : CHEZY INDUSTRIES SDN. BHD.

Product Description

Type : Top access (side flow) floor gully with side inlet and without membrane

Type of floor gully with side inlet : Type II
Nominal size of outlet : DN(ID)50
Nominal size of side inlet : DN(ID)40 / DN(ID)20
Number of side inlet : 3
Thermal behavior : Class A
Loading strength : K 3, H 1,5
Depth of water seal : 50mm
Material : Body - uPVC
Cap - uPVC
Side flow trap - Polypropylene (PP)
Side flow trap cap - Polypropylene (PP)

Certificate No. : L01621
Date of Initial Certification : 16.03.2021
Date of Issue : 04.03.2022
Date of Expiry : 31.03.2023


.....
AZMAN BIN IDRIS
Managing Director
ANQAS CERTIFICATION SDN. BHD.

